IEC 61850 Certificate - IEC 61850 Certificate #3017

DS Agile Gateway [GE Grid Solutions]

07/08/2021 06:15 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10016209-OPE/INC 16-2526
61850 Tested Aspects:	Server	**Certificate Hash:**	E1A2C3720361B44409FB8DBAEDCF4763670D7E2B38757670BD49C605675936C0
Company:	GE Grid Solutions	**Vendor Artifact File Name:**	
Address:	Parc Eurêka 81, rue Euclide – CS 11140 34060 Montpellier cedex 2 France	**Vendor Artifact Hash:**	
Product:	DS Agile Gateway	**Umbrella Organization:**	
HW Version:	UNO A30x	**Optional Reservation Test:**	No
SW Version:	DS Agile V7	**Serial Number:**	
Key Words:	Comm	**Publisher Legacy Variants:**	
Test Procedure Version:	1.2.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	12/05/2016	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

16-2526_DNVGL_GE_GRIDSOLUTIONS_DSAGILE_Gateway_Server_Ed2_IC	90.7 KB	07/08/2021	Herbert Falk