

IEC 61850 Certificate - IEC 61850 Certificate #3017

DS Agile Gateway [GE Grid Solutions]

07/08/2021 06:15 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10016209-OPE/INC 16-2526
61850 Edition:	Edition 2	Certificate Hash:	E1A2C3720361B44409FB8DBAEDCF47 63670D7E2B38757670BD49C60567593 6C0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Grid Solutions	Vendor Artifact Hash:	
Address:	Parc Eurêka 81, rue Euclide – CS 11140 34060 Montpellier cedex 2 France	Umbrella Organization:	
Product:	DS Agile Gateway	Optional Reservation Test:	No
HW Version:	UNO A30x	Serial Number:	
SW Version:	DS Agile V7	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/05/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

16-2526_DNVGL_GE_GRID SOLUTIONS_DSAGILE_Gateway_Server_Certificate.pdf 07/08/2021

Herbert Falk