

IEC 61850 Certificate - IEC 61850 Certificate #3018

REC670 Bay Control [ABB AB]

07/09/2021 06:56 AM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10021419-OPE/INC 16-2464
61850 Edition:	Edition 2	Certificate Hash:	3CE56F4EA900802A9EEB37BE7D653F55FC48FDC4D0E5680E07D07DD01BF075CB
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB	Vendor Artifact Hash:	
Address:	GA Products S-721 59 Västerås Sweden	Umbrella Organization:	
Product:	REC670 Bay Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.2.0.31	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/17/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/09/2021 07:02 AM - Herbert Falk

- File 16-2464_DNVGL_ABB_REC670_REx670_REx650_ServerEd2_Certificate.pdf added
- Address updated
- SW Version set to 2.2.0.31
- Test Procedure Version set to 1.2
- Certificate/Result Reviewer set to bruce.muschlitz,bruce.muschlitz
- Approval Date set to 12/17/2016
- Current Test Lab Name set to DNV Netherlands (A)
- Certificate Name set to 10021419-OPE/INC 16-2464

- Certificate Hash set to 3CE56F4EA900802A9EEB37BE7D653F55FC48FDC4D0E5680E07D07DD01BF075CB
- 61850 Edition Edition 2 added
- 61850 Edition deleted (Edition 2 Amd 1)
- Key Words Bay Controller added
- IEC 61850 Blocks Certified Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) added
- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

#2 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

16-2464_DNVGL_ABB_REC670_REx670_REx650_ServerEd2_Certificate.k05	07/09/2021	Herbert Falk
--	------------	--------------