

IEC 61850 Certificate - IEC 61850 Certificate #3028

UR N60 Network Stability and Synchrophas [GE Grid Automation]

07/09/2021 12:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6UR.801
61850 Edition:	Edition 2	Certificate Hash:	03A2E79521AB336035494EFDC1041E 50B16D4055B1437BA489E939CA47914 D8D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Grid Automation	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C OM1, Canada	Umbrella Organization:	
Product:	UR N60 Network Stability and Synchrophas	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	7.41	Publisher Legacy Variants:	
Key Words:	Measurement, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/06/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6UR_801_GE_UR_Edition2_Certificate.pdf

3.19 MB

07/09/2021

Herbert Falk