

IEC 61850 Certificate - IEC 61850 Certificate #3033

DS Agile C264 Modular Substation / Bay Controller [GE Grid Solutions]

07/09/2021 01:33 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10032235-INC 17-1802
61850 Edition:	Edition 2	Certificate Hash:	C0FC76E62B3F5779E9ADAA2CA01109 0B5A9E382C315DAF75CE7EF58270EE AADE
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	GE Grid Solutions	Vendor Artifact Hash:	
Address:	Parc Eurêka 81, rue Euclide – CS 11140 34060 Montpellier cedex 2 France	Umbrella Organization:	
Product:	DS Agile C264 Modular Substation / Bay Controller	Optional Reservation Test:	Yes
HW Version:	CPUv4	Serial Number:	
SW Version:	DS Agile V7	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	1.0.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/19/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

#2 - 07/11/2021 10:19 AM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

Files

17-1802_DNV_GL_GE_Grid_Solutions_C264_ClientEd2_Certificate.pdf 69.7 KB

07/09/2021

Herbert Falk