

IEC 61850 Certificate - IEC 61850 Certificate #3034

UC 500 Station Server [EFACEC]

07/09/2021 01:39 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 84000155-OPE/INC 17-2420
61850 Tested Aspects:	Client	Certificate Hash: 060818E4232A52A5DBF3B54FEFF1894374B8BE1B5004BC417B0C6299D202A311
Company:	EFACEC	Vendor Artifact File Name:
Address:	Eléctricos, S.A. Rua Eng. Frederico Ulrich Guardediras Apartado 3078 4471-907 Moreira da Maia Portugal	Vendor Artifact Hash:
Product:	UC 500 Station Server	Umbrella Organization:
HW Version:	MOXA Industrial Embedded	Optional Reservation Test: Yes
SW Version:		Serial Number:
Key Words:	Gateway	Publisher Legacy Variants:
Test Procedure Version:	1.0.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	07/26/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description		

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

#2 - 07/11/2021 10:20 AM - Herbert Falk

- *Optional Reservation Test* changed from No to Yes

Files

17-2420_DNVGL_Efacec_UC 500_ClientEd2_certificate.pdf	91 KB	07/09/2021	Herbert Falk
---	-------	------------	--------------