

# IEC 61850 Certificate - IEC 61850 Certificate #3035

## TPU T500 High-end transformer protection [EFACEC]

07/09/2021 01:50 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	84000167-OPE/INC 17-2551
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	267F7DBEA24879CDD799E5AE5F956A EFE3A64D1613D15FC96F37A2996103 8556
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	EFACEC	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Eléctricos, S.A. Rua Eng. Frederico Ulrich Guarderas Apartado 3078 4471-907 Moreira da Maia Portugal	<b>Umbrella Organization:</b>	
<b>Product:</b>	TPU T500 High-end transformer protection	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	MAP8001	<b>Serial Number:</b>	
<b>SW Version:</b>	1.11.000	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), Time Synchronization (B13)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	10/04/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

17-2551\_DNVGL\_EFACEC TPU, TCU, BCU\_ServerEd2\_Certificate.pdf 3.2 KB

07/09/2021

Herbert Falk