

IEC 61850 Certificate - IEC 61850 Certificate #3036

TPU S430 Multifunction protection and co [EFACEC]

07/10/2021 11:24 AM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	84000167-OPE/INC 17-2549
61850 Edition:	Edition 2	Certificate Hash:	C494F07FF1F1E8CE6921A08A140237 AE00841948BB6921DDB811720BB98C 4672
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	EFACEC	Vendor Artifact Hash:	
Address:	Eléctricos, S.A. Rua Eng. Frederico Ulrich Guarderas Apartado 3078 4471-907 Moreira da Maia Portugal	Umbrella Organization:	
Product:	TPU S430 Multifunction protection and co	Optional Reservation Test:	No
HW Version:	MAP8100	Serial Number:	
SW Version:	2.04.000	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/04/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

Migrated

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

17-2549_DNVGL_EFACEC TPU S430-S220-M220_ServerEd2_Certificate.pdf

07/10/2021

Herbert Falk