

IEC 61850 Certificate - IEC 61850 Certificate #3037

DS Agile Gateway [GE Grid Solutions]

07/10/2021 11:30 AM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10057554-INC 17-2696
61850 Edition:	Edition 2	Certificate Hash:	368A9C59E31015CCA93FFCB3C03908 5F2D7533072031FF388816C5735192A 62D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	GE Grid Solutions	Vendor Artifact Hash:	
Address:	Parc Eurêka 81, rue Euclide – CS 11140 34060 Montpellier cedex 2 France	Umbrella Organization:	
Product:	DS Agile Gateway	Optional Reservation Test:	Yes
HW Version:	UNO A30x	Serial Number:	
SW Version:	DS Agile V7	Publisher Legacy Variants:	
Key Words:	Comm, Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/08/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

#2 - 07/11/2021 10:21 AM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

Files

17-2696-DNV-GL_GE_Grid Solutions_GTW_ClientEd2_Certificate.pdf90.3 KB

07/10/2021

Herbert Falk