

IEC 61850 Certificate - IEC 61850 Certificate #3040

Sherpa R 5000 Modular RTU/IED, MPB 600 c [Núcleo de Comunicaciones y Control S.L.U.]

07/10/2021 11:49 AM - Herbert Falk

| | | | |
|-------------------------------------|---|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 84000213-INC 18-2332 |
| 61850 Edition: | Edition 2 | Certificate Hash: | D65AEA1B83DAD1885B5D262659B288 5B3F4FC7EF2D74B51C4BE7A7111AA2 CDEB |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | Núcleo de Comunicaciones y Control S.L.U. | Vendor Artifact Hash: | |
| Address: | C/ Vía de los Poblados, 7 28033 Madrid Spain | Umbrella Organization: | |
| Product: | Sherpa R 5000 Modular RTU/IED, MPB 600 c | Optional Reservation Test: | No |
| HW Version: | 1200.B421.0 | Serial Number: | |
| SW Version: | 6.1.0 | Publisher Legacy Variants: | |
| Key Words: | RTU | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.2.4 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz,bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 04/10/2018 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Description | | | |
| Migrated | | | |

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-2332_DNVGL_DF Nucleo Sherpa R5000,Compact,CompactP_ServerCertificat.pdf 07/10/2021

Herbert Falk