

IEC 61850 Certificate - IEC 61850 Certificate #3042

REC670 Bay Control [ABB AB]

07/10/2021 12:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10080108-INC 18-2666
61850 Edition:	Edition 2	Certificate Hash:	87EBFA6D5DDDF68419371A8BF3CDB 2F618ECCAC7CFF8AB055BCF2F30C5 F9AFAE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB	Vendor Artifact Hash:	
Address:	GA Products S-721 59 Västerås Sweden	Umbrella Organization:	
Product:	REC670 Bay Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.2.3.10	Publisher Legacy Variants:	
Key Words:	Differential, Distance, IOC, Measurement, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.2.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/06/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-2666_DNVGL_ABB-REC670_ServerEd2_Certificate.pdf	130 KB	07/10/2021	Herbert Falk
--	--------	------------	--------------