

IEC 61850 Certificate - IEC 61850 Certificate #3043

CFP1–A41D1 Feeder Protection Relay [Mitsubishi Electric Corporation]

07/10/2021 01:02 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10077873-INC 18-2320
61850 Edition:	Edition 2	Certificate Hash:	77991216EA26D0B114C2CE3ADC16C6 33EDFC3711D2376DC13096022433B7 F8DF
61850 Tested Aspects:	SCL-ICT, Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Umbrella Organization:	
Product:	CFP1–A41D1 Feeder Protection Relay	Optional Reservation Test:	No
HW Version:	405PQB	Serial Number:	
SW Version:	M-Main=PGKK20 comm=2.0.0.0	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.2.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/29/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-2320_DNVGL_Mitsubishi_CFP_ServerEd2_Certificate.pdf	130 KB	07/10/2021	Herbert Falk
--	--------	------------	--------------