

IEC 61850 Certificate - IEC 61850 Certificate #3044

IRL-F Directional Overcurrent with Sensi [ZIV GRID Automation S.L.]

07/10/2021 01:09 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10111820-INC 18-2847
61850 Edition:	Edition 2	Certificate Hash:	A2F50185144D2437C132F4D7058A4FB 9CADB18308227DD5407F237823CBB2 4C2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZIV GRID Automation S.L.	Vendor Artifact Hash:	
Address:	Parque Tecnológico de Bizkaia, 210 48170 Zamudio, Vizcaya Spain	Umbrella Organization:	
Product:	IRL-F Directional Overcurrent with Sensi	Optional Reservation Test:	No
HW Version:	IRL-F-1BCAAABBA1B	Serial Number:	
SW Version:	0.9.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.2.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/13/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-2847_DNVGL_ZIV_IRL-F_ServerEd2_Certificate.pdf	130 KB	07/10/2021	Herbert Falk
---	--------	------------	--------------