

IEC 61850 Certificate - IEC 61850 Certificate #3046

ADVC3 – Advanced Controller [Schneider Electric Recloser Solutions]

07/10/2021 01:26 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10126823-INC 18-3195
61850 Edition:	Edition 2	Certificate Hash:	5A183EB7BB01987E4BD492079020298 0A9369684D50ACE9E6A3ED64498C05 A5F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Recloser Solutions	Vendor Artifact Hash:	
Address:	80 Schneider Road Eagle Farm, Brisbane QLD 4009, Australia	Umbrella Organization:	Schneider Electric
Product:	ADVC3 – Advanced Controller	Optional Reservation Test:	No
HW Version:	5.90	Serial Number:	
SW Version:	A50-08.00r30739	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.2.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/18/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-3195_DNVGL_Schneider Electric_ADVC Controller_ServerEd2_Certificate.pdf	07/10/2021	Herbert Falk
--	------------	--------------