

IEC 61850 Certificate - IEC 61850 Certificate #3049

Aegis Feederl Motor Protection Relay [M/s Crompton Greaves Limited]

07/10/2021 04:57 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL19TC0006
61850 Edition:	Edition 1	Certificate Hash:	8DB774074872DE8052005C6F43684D5 28D818378C578EFA1305D458761A52 D4D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s Crompton Greaves Limited	Vendor Artifact Hash:	
Address:	A - 3, MIDC - Ambad, Nashik - 422010 INDIA	Umbrella Organization:	
Product:	Aegis Feederl Motor Protection Relay	Optional Reservation Test:	No
HW Version:	10	Serial Number:	
SW Version:	A1 -03-10-51	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/26/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

CPR1-CG Power-Feeder Motor Relay_CPRIBLRMUADSASL19TC00063049 KB

07/10/2021

Herbert Falk