

IEC 61850 Certificate - IEC 61850 Certificate #3051

NSD500M Bay Control Unit [NARI Technology Co., Ltd.]

07/10/2021 05:10 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10124892-INC 18-3170
61850 Edition:	Edition 1	Certificate Hash:	69CC04C282575332BDC15E9EEF5074 3B06AABFE1D7649EEBE75BC06BBC9 5C0C4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	[NARI Technology Co., Ltd	Vendor Artifact Hash:	
Address:	No.19 Chengxin Avenue 211106 Nanjing People's Republic of China	Umbrella Organization:	
Product:	NSD500M Bay Control Unit	Optional Reservation Test:	No
HW Version:	R1.10	Serial Number:	
SW Version:	6.02.1	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	1.2.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/25/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-3170_DNVGL_NARI_TECH_NSD500M_ServerEd2_Certificate.pdf 125 KB

07/10/2021

Herbert Falk