

IEC 61850 Certificate - IEC 61850 Certificate #3052

FCU-320 SVG Measurement and Control Devi [XI'AN GENTLE MELLOW TECHNOLOGY CO.,LTD.]

07/10/2021 05:15 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2019PUCA0005
61850 Edition:	Edition 1	Certificate Hash:	1F235D760E0E0B100181DE956B6BD5 4C7F079CD53363F7C0D2F0365767EE 7D43
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	[XI'AN GENTLE MELLOW TECHNOLOGY CO.,LTD.	Vendor Artifact Hash:	
Address:	NO.2,West Side Rd of West 3rd Ring Rd,Hi-tech Industries Development Zone,Xi'an,China	Umbrella Organization:	
Product:	FCU-320 SVG Measurement and Control Devi	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GMT-SVG V1.0	Publisher Legacy Variants:	
Key Words:	Comm, Measurement	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/22/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

Xi_an Gentle mellow_FCU-320 GMT-SVG V1.0_2019PUCA0005_KETOP.AMB 07/10/2021 Herbert Falk