

IEC 61850 Certificate - IEC 61850 Certificate #3054

SEPCOS Control & Protection Relay [Secheron SA]

07/10/2021 05:25 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10160027-INC 19-3195
61850 Edition:	Edition 2	Certificate Hash:	960A5447FACAA8A0C4EB51214107FB 7251F6C8CE960DB8E43409E1BF806F F561
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Secheron SA	Vendor Artifact Hash:	
Address:	Rue du Pré-Bouvier 25 1242 Satigny – Geneva Switzerland	Umbrella Organization:	
Product:	SEPCOS Control & Protection Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	8.10-1	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	1.2.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/17/2019	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

19-3195_DNVGL_Secheron_SEPCOS_ServerEd2_Certificate.pdf	116 KB	07/10/2021	Herbert Falk
---	--------	------------	--------------