

# IEC 61850 Certificate - IEC 61850 Certificate #3055

## EFD500 Earth-Fault Detection Device [Trench]

07/10/2021 05:30 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10174005-INC 20-2283
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	8561E641688B3488B13E45D17859AE5 B1B1A3F7E459F510562E2C3300A8715 A1
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Trench	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Paschinger Straße 49 4060 Leonding Austria	<b>Umbrella Organization:</b>	
<b>Product:</b>	EFD500 Earth-Fault Detection Device	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	EFD:EFDLAN 4.14 ; 61850: 2.14	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.2.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/01/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Migrated			

### History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

20-2283\_DNVGL\_Trench GmbH\_EFD500\_ServerEd2\_Certificate.pdf 115 KB

07/10/2021

Herbert Falk