

# IEC 61850 Certificate - IEC 61850 Certificate #3056

## REC670 Bay Control [ABB AB]

07/10/2021 05:35 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	1KHL050130
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	1E1C284D1744DAB7CC94A3E575B208 3FFEBE2277AF6863EA02E95BEB80 862C
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB AB	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Grid Automation Products S-721 59 Västerås Sweden	<b>Umbrella Organization:</b>	
<b>Product:</b>	REC670 Bay Control	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	2.2.4	<b>Serial Number:</b>	
<b>SW Version:</b>	2.2.10.9	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Bay Controller, Differential, Distance, IOC, Protection, Relay, TOC	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.3a	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/26/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	ABB Switzerland Ltd. (B)		
<b>Description</b>			
Migrated			

### History

#### #1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

1KHL050130\_IEC61850Ed1ConformanceCertificate\_TP3.0.3a\_REC670-2021.pdf 07/10/2021

Herbert Falk