

# IEC 61850 Certificate - IEC 61850 Certificate #3058

## TAPCON ® Voltage Regulator Unit [Maschinenfabrik Reinhausen GmbH]

07/10/2021 05:44 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10202569-INC 20-2457
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	7F93AD287171786DCC1351140A2C09 43024F7E96B36C38616E4EC555B5500 1E9
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Maschinenfabrik Reinhausen GmbH	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Falkensteinstr. 8 93059 Regensburg Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	TAPCON ® Voltage Regulator Unit	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.22	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm, Measurement, RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0_rev4	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/10/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Migrated			

### History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

20-2457_DNV_GL_MR_TAPCON_ServerEd2_Certificate.pdf	115 KB	07/10/2021	Herbert Falk
--	--------	------------	--------------