

IEC 61850 Certificate - IEC 61850 Certificate #3062

RTU7M Modular Control System [ELVAC a.s.]

07/10/2021 05:50 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10202705-INC 20-2382
61850 Edition:	Edition 2	Certificate Hash:	AD0ED88CC4CA934E3B2F3F8291EE7 971FE22B8FFF10388D44C31537CB5A B118D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ELVAC a.s.	Vendor Artifact Hash:	
Address:	Hasicksa 930/53 700 30 Ostrava - Hrabuvka Czech Republic	Umbrella Organization:	
Product:	RTU7M Modular Control System	Optional Reservation Test:	No
HW Version:	67247 550442 110218	Serial Number:	
SW Version:	205.13	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/25/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Migrated			

History

#1 - 07/10/2021 05:51 PM - Herbert Falk

- File 20-2382-DNV_GL_ELVAC_RTU7M_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

20-2382-DNV_GL_ELVAC_RTU7M_ClientEd2_Certificate.pdf	114 KB	07/10/2021	Herbert Falk
--	--------	------------	--------------