

IEC 61850 Certificate - IEC 61850 Certificate #3063

ACOS 750 CU74D Automation and Telecontro [Vivavis AG]

07/10/2021 06:07 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10245671-INC 20-2867
61850 Edition:	Edition 2	Certificate Hash:	35D59F84FB34EE2401949A22B9EDEA AD6D185BB0F39C68445D79BD74E20A 24E8
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Vivavis AG	Vendor Artifact Hash:	
Address:	NobelstraBe 18 D-76275 Ettlingen Germany	Umbrella Organization:	
Product:	ACOS 750 CU74D Automation and Telecontro	Optional Reservation Test:	No
HW Version:	01.01.02	Serial Number:	
SW Version:	7.5.1	Publisher Legacy Variants:	
Key Words:	Gateway, RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/27/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

20-2867_DNV-GL_VIVAVIS_ACOS_750_CU74D_ClientEd2_Certificate.pdf	10 KB	07/10/2021	Herbert Falk
---	-------	------------	--------------