

# IEC 61850 Certificate - IEC 61850 Certificate #3065

## Arkens PR FEEDER FR 42 TE Multipurpose d [SCLE SFE]

07/10/2021 06:18 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10249956-INC 20-2910
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	90FDC6DB3DBE8A2F09F43C906C605 3CB26AB5F773CFCBD6482DFF29F064 D515C
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SCLE SFE	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	25 chemin de Paleficat BP 30407 31204 TOULOUSE Cedex 2 France	<b>Umbrella Organization:</b>	
<b>Product:</b>	Arkens PR FEEDER FR 42 TE Multipurpose d	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	v1.2.0	<b>Serial Number:</b>	
<b>SW Version:</b>	ARM: 3.2a; DSP:3.3a; FPGA: 2.2a	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	IOC, Protection, Relay, TOC	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0_rev4	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/10/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Migrated			

### History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

20-2910\_DNVGL\_SCLE SFE\_Arkens\_PR\_Feeder\_FR\_42\_TE\_ServerEd12\_Certificate.pdf 07/10/2021

Herbert Falk