IEC 61850 Certificate - IEC 61850 Certificate #3065

Arkens PR FEEDER FR 42 TE Multipurpose d [SCLE SFE]

07/10/2021 06:18 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10249956-INC 20-2910
61850 Tested Aspects:	Server	**Certificate Hash:**	90FDC6DB3DBE8A2F09F43C906C6053CB26AB5F773CFCBD6482DFF29F064D515C
Company:	SCLE SFE	**Vendor Artifact File Name:**	
Address:	25 chemin de Paleficat BP 30407 31204 TOULOUSE Cedex 2 France	**Vendor Artifact Hash:**	
Product:	Arkens PR FEEDER FR 42 TE Multipurpose d	**Umbrella Organization:**	
HW Version:	v1.2.0	**Optional Reservation Test:**	No
SW Version:	ARM: 3.2a; DSP:3.3a; FPGA: 2.2a	**Serial Number:**	
Key Words:	IOC, Protection, Relay, TOC	**Publisher Legacy Variants:**	
Test Procedure Version:	2.0_rev4	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	12/10/2020	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

Migrated

History

#1 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

20-2910_DNVGL_SCLE SFE_Arkens_PR_Feeder_FR_42_TE_Server_Ed2_IEC61850_Certificate.pdf	512 KB	07/10/2021	Herbert Falk