

IEC 61850 Certificate - IEC 61850 Certificate #3066

EuroProt+ (IED-EP+) DTVA High-voltage di [Protecta Electronics Co. Ltd.]

07/10/2021 06:46 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10261711-INC 20-3068
61850 Edition:	Edition 2	Certificate Hash:	44DD8DAF089255ED4A356D8B215132 6434F6EFD9ED0E6E2A7F6B6521887D 4395
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Protecta Electronics Co. Ltd.	Vendor Artifact Hash:	
Address:	Kesmark str. 7/A 1158 Budapest Hungary	Umbrella Organization:	
Product:	EuroProt+ (IED-EP+) DTVA High-voltage di	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.10 revision 1.3000	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/19/2020		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

20-3068_DNVGL_Protecta_EuroprotPLUS_ServerEd2_Certificate.pdf 117 KB

07/10/2021

Herbert Falk