

IEC 61850 Certificate - IEC 61850 Certificate #3067

TOR 200 JI 22 3332-16 P (TOP 200) [Relematika, LLC]

07/10/2021 06:54 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10270573-INC 20-3209
61850 Edition:	Edition 2	Certificate Hash:	A19AC18E6BED75D61E34AD1D17C9E 4946F340303630AFD962BD3B48ACF1 1C87E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Relematika, LLC	Vendor Artifact Hash:	
Address:	1 Yakovlev prospect 428020 Cheboksary Russian Federation	Umbrella Organization:	
Product:	TOR 200 JI 22 3332-16 P (TOP 200)	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.16.1_A	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/11/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/10/2021 06:54 PM - Herbert Falk

- File 20-3209_DNVGL_Relematika_TOR200_ServerEd2_Certificate.pdf added

#2 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

20-3209_DNVGL_Relematika_TOR200_ServerEd2_Certificate.pdf	122 KB	07/10/2021	Herbert Falk
---	--------	------------	--------------