

IEC 61850 Certificate - IEC 61850 Certificate #3069

Saitel DP: SM_CPU866e w/ DI32,DO16R,AI16 [Schneider Electric Espana, S.A.]

07/10/2021 07:04 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10250718-INC 21-2691
61850 Edition:	Edition 2	Certificate Hash:	4902B961893E86A24868535C3C5D12C 3208C8C8A72B2F591D7FEC4BCA6673 7B2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Espana, S.A.	Vendor Artifact Hash:	
Address:	C/ Charles Darwin s.n. (Edificio Bogaris) 41092 Sevilla Spain	Umbrella Organization:	Schneider Electric
Product:	Saitel DP: SM_CPU866e w/ DI32,DO16R,AI16	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	11.06.20_2102111515	Publisher Legacy Variants:	
Key Words:	Gateway, Measurement, RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/26/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

21-2691_DNVGL_Schneider_Saitel_DP_ServerEd2_Certificate.pdf 116 KB 07/11/2021 Herbert Falk