

IEC 61850 Certificate - IEC 61850 Certificate #3070

EFC60s Earth-Fault Compensation Controll [Trench]

07/10/2021 07:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10283658-INC 21-2727
61850 Edition:	Edition 2	Certificate Hash:	EE5C5FAD7FCD81531B4FCA299FF71 8A42914D88878C5A3FAF456B2B8A85 18DB4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Trench	Vendor Artifact Hash:	
Address:	Paschinger StraBe 49 4060 Leonding Austria	Umbrella Organization:	
Product:	EFC60s Earth-Fault Compensation Controll	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	E-EFC V2.00 (2021-02-04)	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/01/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

21-2727_DNV_Trench_EFC60s_ServerEd2_Certificate.pdf	115 KB	07/11/2021	Herbert Falk
---	--------	------------	--------------