

IEC 61850 Certificate - IEC 61850 Certificate #3074

IRFA Feeder Protection / Bay Control [ZIV GRID Automation S.L.]

07/10/2021 07:51 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10282777-INC 21-2971
61850 Edition:	Edition 2	Certificate Hash:	33696F52DED2049AFFB55D52C58AE0 2FD3827425BE707DB514B786591EC9 241A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZIV GRID Automation S.L.	Vendor Artifact Hash:	
Address:	Parque Tecnologico de Bizkaia, 210 48170 Zamudio, Vizcaya Spain	Umbrella Organization:	
Product:	IRFA Feeder Protection / Bay Control	Optional Reservation Test:	No
HW Version:	IRFA-2A24322A000000C010	Serial Number:	
SW Version:	0.10.0	Publisher Legacy Variants:	
Key Words:	Bay Controller, Differential, Distance, IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/10/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

21-2971_DNV_ZIV_IRF_RTF_IDF_ZLF_DLF_ServerEd2_Certificate.pdf 20 KB

07/11/2021

Herbert Falk