

IEC 61850 Certificate - IEC 61850 Certificate #3075

REC670 Bay Control Unit version 2.2.5 [Hitachi ABB Power Grids]

07/10/2021 07:56 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Test Document:
61850 Tested Aspects:	Server	Certificate Name: 1KHL050134
Company:	Hitachi ABB Power Grids	Certificate Hash: 2F2F7758C92F91E1BFF753ABF72AEE AEA43ADF13C749151B77AF58280189 7E3D
Address:	GA Products S-721 59 Västerås Sweden	Vendor Artifact File Name:
Product:	REC670 Bay Control Unit version 2.2.5	Vendor Artifact Hash:
HW Version:	2.2.5	Umbrella Organization:
SW Version:	2.2.14.2	Optional Reservation Test: No
Key Words:	Differential, IOC, Measurement, Protection, Relay, TOC	Serial Number:
Test Procedure Version:	3.3a	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	06/25/2021	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:		Subscriber Preferred Rates:
Description		

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

1KHL050134_IEC61850Ed1ConformanceCertificate_TP3.0.3a_REC670-2.2.5.pdf	07/11/2021	Herbert Falk
--	------------	--------------