

IEC 61850 Certificate - IEC 61850 Certificate #3076

ProField-HE Substation Automation Gateway [Prolan Power Zrt]

07/10/2021 08:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10280174-INC 21-2889
61850 Edition:	Edition 2	Certificate Hash:	D4B20EDDC94F49F501A75A54AFAF70 AE4EEE75EC67A49202CBB6FB984263 A596
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Prolan Power Zrt	Vendor Artifact Hash:	
Address:	Szentendrei ut 1-3 2011 Budakalasz Hungary	Umbrella Organization:	Prolan
Product:	ProField-HE Substation Automation Gateway	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	SW: IMG 2.0.0; 61850: SAG 4.0.0	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/25/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

#2 - 07/30/2021 12:37 PM - Bruce Muschlitz

- Umbrella Organization set to Prolan

Files

21-2889_DNV_Prolan_ProfieldHE_ServerEd2_Certificate.pdf	118 KB	07/11/2021	Herbert Falk
---	--------	------------	--------------