

# IEC 61850 Certificate - IEC 61850 Certificate #3077

## REC670 Bay Control [Hitachi ABB Power Grids]

07/10/2021 08:07 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10289889-INC 21-2985
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	81CA7149EB9B90395619342F54C4A7 CBD9879DDC522B5121A87E5FBA1A4 A5B35
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Hitachi ABB Power Grids	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	ABB Power Grids Sweden AB GA Products S-721 59 Vasteras Sweden	<b>Umbrella Organization:</b>	
<b>Product:</b>	REC670 Bay Control	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	2.2.5	<b>Serial Number:</b>	
<b>SW Version:</b>	2.2.14.5	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Bay Controller, Differential, Distance, IOC, Measurement, Protection, Relay, TOC	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>		<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/30/2021	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

### Files

21-2985\_DNV\_ABB\_REC670\_ServerEd2\_Certificate.pdf

120 KB

07/11/2021

Herbert Falk