IEC 61850 Certificate - IEC 61850 Certificate #3078

Easergy P3U30 Protection relay [Schneider Electric]

07/11/2021 09:55 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10072000-INC 18-2173 Rev1
61850 Tested Aspects:	Server	**Certificate Hash:**	CCCF87355B46097BD22891ECDE19E725691D9885AC20F843E36A3893DE56D354
Company:	Schneider Electric	**Vendor Artifact File Name:**	
Address:	A-600, TTC Industrial Area Shil - Mahape Road Navi Mumbai - 400710 India	**Vendor Artifact Hash:**	
Product:	Easergy P3U30 Protection relay	**Umbrella Organization:**	Schneider Electric
HW Version:	P3U30-5AAA1BCA	**Optional Reservation Test:**	No
SW Version:	V30.105	**Serial Number:**	
Key Words:	Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.2.4	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	05/07/2018	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

18-2173_Rev1_DNVGL_SchneiderElectric_P3U30_P3F30_P3G30_P3U32_P3L30_P3U30_P3U32_P3T32__P3U20_ServerEd2_Certificate_rev1.pdf	393 KB	07/11/2021	Herbert Falk