

## Server - Issues #3079

### sSvp13 Quality bit invalid - change to Conditional

07/12/2021 04:46 AM - Richard Schimmel

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b>	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> Ed2Amd1 TP1.1
<b>Clause Reference:</b>	<b>Test Case ID:</b> sSvp13
<b>61850 Standard:</b> 9-2	<b>Closed Reason:</b> Test Procedure Update
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b> sSvp13 now Conditional	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2Amd1 TP1.0	
<b>Description</b>	
test case sSvp13 is related to backwards configuration which <b>may</b> have current/voltage sampled values that are not measured and as such shall have quality=invalid. This is specified in the PIXIT Svp9. The test case should be changed from Mandatory to Conditional.	

#### History

##### #1 - 07/12/2021 04:55 AM - Richard Schimmel

- File Solution to redmine\_3079\_sSvp13.docx added
- Status changed from New to In Progress

##### #2 - 07/12/2021 06:42 AM - Thierry Dufaure

I agree with the proposed changes by Richard.

##### #3 - 07/27/2021 08:51 AM - Richard Schimmel

- Status changed from In Progress to Resolved
- Final Decision set to sSvp13 now Conditional

TPWG agreement resolved

##### #4 - 09/14/2021 06:41 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Initial Test Document changed from Amd1 to Ed2Amd1 TP1.0
- Updated Test Document set to Ed2Amd1 TP1.1
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

##### #5 - 06/14/2022 08:31 AM - Bruce Muschlitz

- Discuss in Upcoming Meeting changed from Yes to No

#### Files

Solution to redmine_3079_sSvp13.docx	178 KB	07/12/2021	Richard Schimmel
--------------------------------------	--------	------------	------------------