

# IEC 61850 Certificate - IEC 61850 Certificate #3080

## Saitel DR: HUe with AB\_DIDO and AB\_AI [Schneider Electric Espana, S.A.]

07/12/2021 11:15 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10266325-INC 21-3072
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	ED79A0D326DEC9E2732C694CBBB3B DA1B02BB6F9DB21D76DABDD531FC3 ADE6F8
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric Espana, S.A.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	C/ Charles Darwin s.n. Edificio Bogaris 41092 Sevilla Spain	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Saitel DR: HUe with AB_DIDO and AB_AI	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	11.07.01_2106080734	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/18/2021	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Remote Terminal Unit & Controller with high performance CPU, digital inputs, digital outputs, and analog inputs module			

### Files

21-3072_DNV_Schneider_Saitel_DR_clientEd2_Certificate.pdf	121 KB	07/12/2021	Bruce Muschlitz
---	--------	------------	-----------------