

IEC 61850 Certificate - IEC 61850 Certificate #3082

SITRAS MDC[Siemens Mobility GmbH]

07/13/2021 07:39 PM - Bruce Muschlitz

Status:	Approved	Test Document:	2.0.5
Priority:	Normal	Certificate Name:	10269611-INC 21-2917
61850 Edition:	Edition 2	Certificate Hash:	E0B31507B91916569FC9F93DEAE738 EF8FC200CBC9626E30D097A6517297 2DEA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens Mobility GmbH	Vendor Artifact Hash:	
Address:	Mozartstraße 33b D-91052 Erlangen Germany	Umbrella Organization:	Siemens
Product:	SITRAS MDC	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V1.1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/08/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
DC Protection Device and Controller			

History

#1 - 07/13/2021 07:40 PM - Bruce Muschlitz

- Test Procedure Version set to

http://www.ucaiug.org/org/TechnicalO/Testing/UCAlug%20Testing%20Quality%20Assurance%20Program/Current%20IEC%2061850%20Edition%20%20Testing%20Procedures/UCATestProceduresServer61850-8-1Ed2_Rev2p0p5.pdf

#2 - 07/14/2021 06:27 AM - Herbert Falk

- Test Procedure Version changed from

http://www.ucaiug.org/org/TechnicalO/Testing/UCAlug%20Testing%20Quality%20Assurance%20Program/Current%20IEC%2061850%20Edition%20%20Testing%20Procedures/UCATestProceduresServer61850-8-1Ed2_Rev2p0p5.pdf to 2.0.5

#3 - 07/22/2021 09:33 AM - Bruce Muschlitz

- Test Document changed from

Files

21-2917_DNV_Siemens_SITRAS_MDC_ServerEd2_Certificate.pdf	117 KB	07/14/2021	Bruce Muschlitz
--	--------	------------	-----------------