

IEC 61850 Certificate - IEC 61850 Certificate #3086

EcoStruxure Power Operation [Schneider Electric]

07/22/2021 09:31 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10027444-INC 21-3160
61850 Edition:	Edition 2	Certificate Hash:	F8C6CA754A084567562D120F3292864 A1F9F56DD4CD983E9C08CDBCF9DB7 8BA4
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	35 Rue Joseph Monier 92500 Rueil-Malmaison France	Umbrella Organization:	Schneider Electric
Product:	EcoStruxure Power Operation	Optional Reservation Test:	No
HW Version:	Oracle VM Virtualbox with Windows server 2019 Standard with Driver version: 1.7.8	Serial Number:	
SW Version:	2021	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/22/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

Edge control software for managing critical facilities

History

#1 - 07/22/2021 09:55 AM - Bruce Muschlitz

- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

Files

21-3160_DNV_Schneider Electric_EcoStruxure Power Operation_client EOC Certificate 07/22/2021

Bruce Muschlitz