

# IEC 61850 Certificate - IEC 61850 Certificate #3088

## CSEZen-F\_M\_T-XXX [M/s. C&S Electric Ltd.]

07/27/2021 01:23 PM - Bruce Muschlitz

|   |  |                                       |  |
|---|--|---------------------------------------|--|
| <b>Status:</b>  | Approved   | <b>Test Document:</b>                 |  |
| <b>Priority:</b>  | Normal   | <b>Certificate Name:</b>              | CPRIBLRMUADSASL21TC0002  |
| <b>61850 Edition:</b>                                     | Edition 2  | <b>Certificate Hash:</b>              | 399E6E080E22FAD141A7DD28B95921<br>5CCFE40347A90284D59A5382DBA75B<br>3218 |
| <b>61850 Tested Aspects:</b>                              | Server   | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>   | M/s. C&S Electric Ltd.   | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>   | C-60, Wing - A (Opposite Parag Dairy)<br>Phase- II, NOIDA- 201305<br>Dist: Gautam Budh Nagar,<br>UP-INDIA  | <b>Umbrella Organization:</b>         | M/s. C&S Electric Ltd.   |
| <b>Product:</b>   | CSEZen-F_M_T-XXX   | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>  | 1.2.0.00.00  | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>  | ZC0.0.00.55  | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>   | Differential, IOC, Protection, Relay, TOC  | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>                            | 2.0.2  | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>                        | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b>                       | Bruce.Muschlitz  | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>                                     | 07/23/2021   | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>                                  | 61850-6, 61850-7-1, 61850-7-2,<br>61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>                             | Central Power Research Institute India (A)   |                                       |  |
| <b>Description</b>  |  |                                       |  |
| Multifunctional Feeder Motor Transformer Protection Relay |  |                                       |  |

### History

#1 - 08/03/2021 10:52 AM - Bruce Muschlitz

- Approval Date changed from 07/27/2021 to 07/23/2021

### Files

CandS Electric Ltd - CPRIBLRMUADSASLTC0002.pdf

1.61 MB

07/27/2021

Bruce Muschlitz