

IEC 61850 Certificate - IEC 61850 Certificate #3092

Saitel DR: HUe with AB_DIDO and AB_AI [Schneider Electric España, S.A.]

08/05/2021 09:01 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10266325-INC 21-3191
61850 Edition:	Edition 2	Certificate Hash:	D332D56B0F107512F37FA2C3D64607 9E7B69874DED7D7D8E742D11B54B80 6569
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric España, S.A.	Vendor Artifact Hash:	
Address:	C/ Charles Darwin s.n. (Edificio Bogaris) 41092 Sevilla Spain	Umbrella Organization:	Schneider Electric
Product:	Saitel DR: HUe with AB_DIDO and AB_AI	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	11.07.01_2106221139	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/23/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Remote Terminal Unit & Controller with high performance CPU, digital inputs, digital outputs, and analog inputs module			

Files

21-3191_DNV_Schneider_Saitel_DR_ServerEd2_Certificate.pdf	122 KB	08/05/2021	Bruce Muschlitz
---	--------	------------	-----------------