

IEC 61850 Certificate - IEC 61850 Certificate #3096

H-SEAM- Client [Hyosung Heavy Industries Co., LTD.]

08/05/2021 02:08 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-069592-02-1
61850 Edition:	Edition 2	Certificate Hash:	
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Hyosung Heavy Industries Co., LTD.	Vendor Artifact Hash:	
Address:	119, Mapo-daero (Gongdeok-dong), Mapo-gu, Seoul, Republic of Korea, 04144	Umbrella Organization:	Hyosung
Product:	H-SEAM- Client	Optional Reservation Test:	No
HW Version:	DELL LBHW2SDLR	Serial Number:	
SW Version:	14.0	Publisher Legacy Variants:	
Key Words:	HMI	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/05/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
HMI Client			

History

#1 - 08/05/2021 02:12 PM - Bruce Muschlitz

- Certificate/Result Reviewer set to Bruce.Muschlitz
- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

#2 - 08/06/2021 09:21 AM - Bruce Muschlitz

- File 20-069592-02-1_Hyosung Heavy Industries_H-SEAM-Client_Client_Ed2_Certificate_KTL.pdf added

#3 - 08/06/2021 09:21 AM - Bruce Muschlitz

- File deleted (20-069592-02-1_Hyosung Heavy Industries_H-SEAM-Client_Client_Ed2_Certificate_KTL.pdf)

Files

20-069592-02-1_Hyosung Heavy Industries_H-SEAM-Client_Client_Eco-Declare_KOR.pdf

Bruce Muschlitz