

IEC 61850 Certificate - IEC 61850 Certificate #3108

SAS-PYLON-V2 [PNC Technologies Co., Ltd.]

09/02/2021 02:21 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21-052539-01-1
61850 Edition:	Edition 2	Certificate Hash:	6545F22BF2F1FE1779AE8F7838BE1F8 CB923930520BEDE6B98A271D2FF31D EEC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, 14042, Republic of Korea	Umbrella Organization:	PNC
Product:	SAS-PYLON-V2	Optional Reservation Test:	
HW Version:	ECU-4784 Windows Server 2016	Serial Number:	
SW Version:	2.1	Publisher Legacy Variants:	
Key Words:	Bay Controller, Comm	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/02/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description Substation Automation System			

Files

21-052539-01-1_PNCTech_SAS-PYLON-V2_Server_Ed2_Certification.pdf 9.4 KB 09/02/2021 Bruce Muschlitz