

IEC 61850 Certificate - IEC 61850 Certificate #3111

Delta Grid [Delta Electronics, Inc.]

09/08/2021 02:12 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21-03-CAV-020-01a
61850 Edition:	Edition 2	Certificate Hash:	CB621578A26610E68747346E028FE78 A30D69406CBF2AEE888D1775ACEFF 5F2B
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Delta Electronics, Inc.	Vendor Artifact Hash:	
Address:	No. 16, Tungyuan Road, Zhongli District, Taoyuan City 320, Taiwan	Umbrella Organization:	Delta
Product:	Delta Grid	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	V1.1.0	Publisher Legacy Variants:	
Key Words:	Comm, HMI	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/08/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Taiwan Testing and Certification Center (A)		
Description energy management gateway/site controller			

History

#1 - 09/08/2021 02:22 PM - Bruce Muschlitz

- IEC 61850 Blocks Certified Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5) added

Files

21-03-CAV-020-01a Delta Grid IEC 61850 Client_Certificate.pdf	1.17 MB	09/08/2021	Bruce Muschlitz
---	---------	------------	-----------------