

IEC 61850 Certificate - IEC 61850 Certificate #3113

PcVue [ARC Informatique]

09/08/2021 04:41 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10298575-INC 21-3211
61850 Edition:	Edition 2	Certificate Hash:	A4B47EF34989CF96865C6C5A5CA78C 9505FA30AA33FF41D11476D7D51284 EA20
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ARC Informatique	Vendor Artifact Hash:	
Address:	2 avenue de la Cristallerie 92310 Sèvres France	Umbrella Organization:	ARC Informatique
Product:	PcVue	Optional Reservation Test:	Yes
HW Version:	Dell Precision Tower 3620 Windows Server 2019 Standard	Serial Number:	
SW Version:	15.1.3	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:		Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/02/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Platform for IoT, SCADA, BMS & real time Data analytics			

Files

21-3211_DNV_ARC Informatique_PC_Vue_clientEd2_Certificate.pdf 121 KB

09/08/2021

Bruce Muschlitz