

WG13 Issues - CIM Issues #3932

Text corrections for SvInjection

1) SvInjection.pNetInjecti

09/14/2021 03:43 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Lars-Ola Osterlund	Standard(s):
Base Release:	Version:
Solution to be Applied To: 61970cim15v03 61968cim11v02	Clause:
Solution Version: CIM15	Sub-Clause:
Solution Applied By: LOO	Paragraph:
Completion Date: 09/29/2010	Table:
CIM Keywords:	Originally Closed in Version: CIM15
Breaking Change: No	Origination Date: 04/28/2010
Breaking Change Description:	Origination ID: 13_7
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description Text corrections for SvInjection 1) SvInjection.pNetInjection old: "The active power injected into the bus at this location." suggested: "The active power injected into the bus at this location. Positive sign means injection into the bus." 2) SvInjection.qNetInjection old: "The active power injected into the bus at this location." (wrong!) suggested: "The reactive power injected into the bus at this location. Positive sign means injection into the bus."	
Proposed Solution Also add the following to description Positive sign means flow into the TopologicalNode.	
Decision Updated as proposed	