

WG13 Issues - CIM Issues #4007

RegulatingControl.Terminal needs some further description i

09/14/2021 03:43 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Kendall Demaree	Standard(s):
Base Release: 61970cim14v15	Version:
Solution to be Applied To: 61970cim15v26	Clause:
Solution Version: CIM16	Sub-Clause:
Solution Applied By: KDD	Paragraph:
Completion Date: 05/26/2011	Table:
CIM Keywords:	Originally Closed in Version: CIM16
Breaking Change: No	Origination Date: 05/16/2011
Breaking Change Description:	Origination ID: 13_53
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description RegulatingControl.Terminal needs some further description in the UML. - Some of the documentation for RegulatingControl.Terminal association could be moved from the IEC61970-452 document into the UML documentation. Present UML documentation says only: "The terminal associated with this regulating control." -- and for Terminal.RegulatingControl -- "The terminal is regulated by a control."	
Proposed Solution Add discussion about how Terminal might "survive" conversions among planning and operations models, and that the terminal of a BusbarSection could also be used.	
Decision KDD corrected.	