

WG13 Issues - CIM Issues #4012

RatioTapChangerTabular and PhaseTapChangertTabular need to

09/14/2021 03:43 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Kendall Demaree	Standard(s):
Base Release: 61970cim15v26	Version:
Solution to be Applied To: 61970cim15v28	Clause:
Solution Version: CIM16	Sub-Clause:
Solution Applied By: KDD	Paragraph:
Completion Date: 06/20/2011	Table:
CIM Keywords:	Originally Closed in Version: CIM16
Breaking Change: No	Origination Date: 06/20/2011
Breaking Change Description:	Origination ID: 13_61
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description RatioTapChangerTabular and PhaseTapChangertTabular need to specialise IdentifiedObject The classes are referenced so should have mRID and name just like other referenced schedules.	
Proposed Solution Add the inheritance.	
Decision (2011-06-22 WG13 issues call) This solution accepted and implemented.	