

WG13 Issues - CIM Issues #4037

Add LineTrap class as AuxilliaryEquipment Need to represent

09/14/2021 03:43 PM - Herbert Falk

Status: Closed	
Priority: Normal	
Target version:	
Author/Contact Info: Kendall Demaree	Standard(s):
Base Release: 61970cim15v33	Version:
Solution to be Applied To: 61970cim16v04	Clause:
Solution Version: CIM16	Sub-Clause:
Solution Applied By: KDD	Paragraph:
Completion Date: 12/16/2011	Table:
CIM Keywords:	Originally Closed in Version: CIM16
Breaking Change: No	Origination Date: 10/27/2011
Breaking Change Description:	Origination ID: 13_101
CIM Impacted Groups: WG13	Originally Assigned To:
Requestor:	
Description Add LineTrap class as AuxilliaryEquipment Need to represent a communications filter as might exist on a an AC line. Note this was duplicate of issue 13_97.	
Proposed Solution Add new class called LineTrap as a specialization of AuxilliaryEquipment. IEC 62488-1standard addresses communications filters.	
Decision Agree to add. Possibly a different name is better, but no suggestions so far. Statnett suggested to use WaveTrap and expressed agreement that Siemens also liked this name. Our WG 13 discussion on 2011-12-14 came to this same conclusion, so modified name to WaveTrap.	