

## IEC 61850 User Feedback Task Force - Feature #405

### Optionality of DO/DA from the point of view of users

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b> Requirement Spec of user	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	<b>To discuss in WG10:</b>
<b>ID:</b> 2.2	<b>Short Proposal:</b> If a user requires a particular DO/DA that is optional (and hence the functionality behind), this needs to be specified as a functional requirement by the user.
<b>Source:</b> ENTSO-E	<b>Standard(s):</b>
<b>TF Unique ID:</b> 2.2 # ENTSO-E	<b>Needs More Information:</b>
<b>WG10 Proposal:</b> The user shall include in the requirement specification for a project, what optional information is needed.	<b>Assigned TF:</b>
<b>Estimated Completion:</b>	
<b>Discuss in Upcoming Meeting:</b> No	

**Description**

There is a misunderstanding of Optionality concept - By the User, Optional means - if it is required by user, it is available (as options).  
By the Vendor/Standard - Optional means - it is not mandatory to implement.

#### History

#1 - 02/03/2021 02:53 PM - Herbert Falk

- Status changed from New to Closed

#2 - 02/11/2021 06:20 AM - Vladan Cvejic

- Description updated

- Discuss in Upcoming Meeting set to No

Checking done.