

WG13 Issues - CIM Issues #4050

GeneratingUnit genOperatingMode attribute : "Operating mode

09/14/2021 03:43 PM - Herbert Falk

Status:	Closed	
Priority:	Normal	
Target version:		
Author/Contact Info:	FR (EDF-EL) FR-2005-34	Standard(s):
Base Release:		Version:
Solution to be Applied To:	61970cim16v15	Clause:
Solution Version:	CIM16	Sub-Clause:
Solution Applied By:	KLH	Paragraph:
Completion Date:	11/28/2012	Table:
CIM Keywords:		Originally Closed in Version: CIM16
Breaking Change:	No	Origination Date: 09/14/2005
Breaking Change Description:		Origination ID: 276
CIM Impacted Groups:	WG13	Originally Assigned To:
Requestor:		

Description

GeneratingUnit genOperatingMode attribute : "Operating mode for secondary control, e.g.: Off, Manual, Fixed, LFC, AGC, EDC, RPN, MRN, or REG"

Roy's WG14 Comments: wg13 issue

Proposed Solution

Explicit the acronyms
20070118/LOO Add documentation describing each mode.

2011-12-14 email to WG13 from KDD
GeneratingUnit seems to be the wrong class for AGC control attributes, you need something like a plant controller or resource controller.

2011-02-16 kdd - suggest removing from Generating unit since this is inappropriate place to put AGC attributes.

Decision

Needs investigation to spell out or explain all the acronyms completely.

2010-12-08/LOO
Assigned to Kendall.

2011-05-26/KDD - move to CIM16

2012-11-07 WG 13 - Agreed to remove the attribute, GeneratingUnit.genOperatingMode, and the enumeration, GeneratorOperatingMode and close the issue.